



RESIDENTIAL GENERATOR SUBMITTAL CHECKLIST

ADDRESS: _____ PERMIT #: _____

Registration: General- _____ ELEC- _____ PLB - _____

Current Codes: 2021 IRC and 2020 NEC

Portable Generator w/Transfer Switch – ELECTRIC PERMIT ONLY

_____ Site plan with Location and Electric route diagram.

_____ **Description on Permit to clearly say Portable Generator**

Permanent Generator – MISCELLANEOUS PERMIT

_____ Site plan with pad Location (All locations must be at least five feet away from openings such as windows, soffit vents, and doorways and any combustibles per NFPA 37 Section 4.1.4)

_____ Show windows and doors within 10 feet

_____ Electric one line diagram and Gas Line route (unless Diesel)

_____ Installation Manual and Owner's Manual

_____ Specs for Generator with UL/ANSI Standards

_____ Transfer Switch Specifications

_____ **Description on Permit to clearly say Permanent Generator**

INSPECTIONS REQUIRED – to be added by the Plans Examiner

Electric Rough In

Plumbing Rough In

Gas Test

Electric Final, Plumbing Final, Building Final

APPLICATION COMPLETE: YES NO (note any missing or incorrect items)

Checklist Reviewed By: _____ Date _____

BUILDING INSPECTIONS, 1400 Main St., Ste. 250, Southlake, TX 76092

Phone: 817-748-8236 or 8237 www.cityofsouthlake.com

February 2023